

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent repair to the existing irrigation tank & Improvement to canal at Gauthan Priol in Priol Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2192						164.44		No. WRD/WD XI/SD IV/ F.CF/144/2020-21. <b>DATED: 22-02-2021</b>
	2193	16-02-2021	16-03-2021	for base	1.2.4	150 kg/cm2	164.44	165.92	
	2194						168.89		
2	2195						168.89		
	2196	17-02-2021	17-03-2021	for base	1.2.4	150 kg/cm2	164.44	167.41	do
	2197						168.89		
3	2198						168.89		
	2199	19-02-2021	19-03-2021	for base	1.2.4	150 kg/cm2	168.89	167.41	do
	2200						164.44		
4	2201						164.44		
	2202	20-02-2021	20-03-2021	for base	1.2.4	150 kg/cm2	164.44	164.44	do
	2203						168.89		