

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	4280						115.56		No. WRD/SD I/WD II/ F.Estt/940/2020-21. DATED: 24-03-2021
	4281	19-03-2021	16-04-2021	Foundation	1.3.6	100 kg/cm2	115.56	112.60	
	4282						106.67		
2	4283						120.00		
	4284	20-03-2021	17-04-2021	Foundation	1.3.6	100 kg/cm2	111.11	114.07	do
	4285						111.11		
3	4286						124.44		
	4287	21-03-2021	18-04-2021	Foundation	1.3.6	100 kg/cm2	111.11	118.52	do
	4288						120.00		
4	4289						120.00		
	4290	22-03-2021	19-04-2021	Foundation	1.3.6	100 kg/cm2	120.00	117.04	do
	4291						111.11		
5	4292						124.44		
	4293	23-03-2021	20-04-2021	Foundation	1.3.6	100 kg/cm2	111.11	115.55	do
	4294						111.11		
6	5624						115.56		No. WRD/SD I/WD II/ F.Estt/37/2021-22. DATED: 16-04-2021
	5625	10/4/2021	8/5/2021	Foundation	1.3.6	100 kg/cm2	115.56	112.60	
	5626						106.67		
7	5627						120.00		
	5628	11/4/2021	9/5/2021	Foundation	1.3.6	100 kg/cm2	111.11	114.07	do
	5629						111.11		
8	5630						124.44		
	5631	12/4/2021	10/5/2021	Foundation	1.3.6	100 kg/cm2	111.11	118.52	do
	5632						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9	5633						124.44		No. WRD/SD I/WD II/ F.Estt/37/2021-22. DATED: 16-04-2021
	5634	13-04-2021	11/5/2021	Foundation	1.3.6	100 kg/cm2	128.89	122.96	
	5635						115.56		
10	5636						124.44		do
	5637	14-04-2021	12/5/2021	Foundation	1.3.6	100 kg/cm2	128.89	124.44	
	5638						120.00		
11	5639						124.44		do
	5640	15-04-2021	13-05-2021	Foundation	1.3.6	100 kg/cm2	115.56	121.48	
	5641						124.44		
12	6311						120.00		No. WRD/SD I/WD II/ F.Estt/62/2021-22. DATED: 23-04-2021
	6312	17-04-2021	15-05-2021	Foundation	1.3.6	100 kg/cm2	120.00	118.52	
	6313						115.56		
13	6314						124.44		do
	6315	19-04-2021	17-05-2021	Foundation	1.3.6	100 kg/cm2	128.89	124.44	
	6316						120.00		
14	6317						120.00		do
	6318	20-04-2021	18-05-2021	Foundation	1.3.6	100 kg/cm2	124.44	118.52	
	6319						111.11		
15	6320						120.00		do
	6321	21-04-2021	19-05-2021	Foundation	1.3.6	100 kg/cm2	124.44	121.48	
	6322						120.00		
16	6323						124.44		do
	6324	22-04-2021	20-05-2021	Foundation	1.3.6	100 kg/cm2	124.44	122.96	
	6325						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17	6698						120.00		No. WRD/SD I/WD II/ F.Estt/83/2021-22.
	6699	26-04-2021	24-05-2021	Foundation	1.3.6	100 kg/cm2	120.00	117.04	
	6700						111.11		DATED: 03-05-2021
18	6701						124.44		
	6702	27-04-2021	25-05-2021	Foundation	1.3.6	100 kg/cm2	111.11	115.55	do
	6703						111.11		
19	6704						115.56		
	6705	28-04-2021	26-05-2021	Foundation	1.3.6	100 kg/cm2	115.56	112.60	do
	6706						106.67		
20	6707						120.00		
	6708	29-04-2021	27-05-2021	Foundation	1.3.6	100 kg/cm2	111.11	114.07	do
	6709						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER