

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 26 in Village Dramapur in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	8600						164.44		No. WRD/SD I/WD II/ F.Esst/190/2021-22. DATED: 01-07-2021
	8601	21-06-2021	19-07-2021	Foundation	1.2.4	150 kg/cm ²	168.89	167.41	
	8602						168.89		
1.2	8603						168.89		do
	8604	21-06-2021	19-07-2021	Foundation	1.2.4	150 kg/cm ²	164.44	165.92	
	8605						164.44		
2.1	8606						168.89		do
	8607	22-06-2021	20-07-2021	Foundation	1.2.4	150 kg/cm ²	168.89	168.89	
	8608						168.89		
2.2	8609						168.89		do
	8610	22-06-2021	20-07-2021	Foundation	1.2.4	150 kg/cm ²	168.89	167.41	
	8611						164.44		
3.1	8612						173.33		do
	8613	23-06-2021	21-07-2021	Foundation	1.2.4	150 kg/cm ²	164.44	168.89	
	8614						168.89		
3.2	8615						168.89		do
	8616	23-06-2021	21-07-2021	Foundation	1.2.4	150 kg/cm ²	168.89	168.89	
	8617						168.89		
4.1	8618						164.44		do
	8619	24-06-2021	22-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	164.44	
	8620						164.44		
4.2	8621						168.89		do
	8622	24-06-2021	22-07-2021	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	8623						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection wall for nallah in Sy.No. 26 in Village Dramapur in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	8624						164.44		No. WRD/SD I/WD II/ F.Esst/190/2021-22. DATED: 01-07-2021
	8625	25-06-2021	23-07-2021	Wall	1.2.4	150 kg/cm ²	168.89	165.92	
	8626						164.44		
5.2	8627						164.44		do
	8628	25-06-2021	23-07-2021	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	8629						168.89		
6.1	8630						168.89		do
	8631	26-06-2021	24-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	165.92	
	8632						164.44		
6.2	8633						168.89		do
	8634	26-06-2021	24-07-2021	Wall	1.2.4	150 kg/cm ²	168.89	167.41	
	8635						164.44		
7.1	8636						168.89		do
	8637	28-06-2021	26-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	167.41	
	8638						168.89		
7.2	8639						168.89		do
	8640	28-06-2021	26-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	165.92	
	8641						164.44		
8	8642						164.44		do
	8643	29-06-2021	27-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	164.44	
	8644						164.44		
9	8645						168.89		do
	8646	30-06-2021	28-07-2021	Wall	1.2.4	150 kg/cm ²	164.44	165.92	
	8647						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER