

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization and Development of Nallah in Sy.No. 29 & 31 at Karally Paroda in Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	6608						111.11		No. WRD/SD I/WD II/ F.Estt/84/2021-22. DATED: 03-05-2021
	6609	28-04-2021	5/5/2021	Foundation & Wall	1.2.4	100 kg/cm2	102.22	111.11	
	6610						120.00		
2	6611						111.11		
	6612	29-04-2021	6/5/2021	Foundation & Wall	1.2.4	100 kg/cm2	111.11	109.63	do
	6613						106.67		
3	6614						111.11		
	6615	30-04-2021	7/5/2021	Foundation & Wall	1.2.4	100 kg/cm2	111.11	112.59	do
	6616						115.56		
4	6617						97.78		
	6618	1/5/2021	8/5/2021	Wall	1.2.4	100 kg/cm2	115.56	111.11	do
	6619						120.00		