

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1430						80.00		No. WRD/WD XI/ SD IV/ F.cf/76/2020-21. DATED: 27-01-2021
	1431	20-01-2021	27-01-2021	LHS Foundation Ch. 0 to 30.00 mt	1.3.6	70 kg/cm2	84.44	82.96	
	1432						84.44		
2	1433						84.44		do
	1434	21-01-2021	28-01-2021	LHS Foundation Ch. 30 to 60.00 mt	1.3.6	70 kg/cm2	84.44	84.44	
	1435						84.44		
3.1	1436						75.56		do
	1437	22-01-2021	29-01-2021	LHS Foundation Ch. 60 to 120.00 mt	1.3.6	70 kg/cm2	80.00	78.52	
	1438						80.00		
3.2	1439						80.00		do
	1440	22-01-2021	29-01-2021	LHS Foundation Ch. 60 to 120.00 mt	1.3.6	70 kg/cm2	75.56	77.04	
	1441						75.56		
4.1	1442						80.00		do
	1443	23-01-2021	30-01-2021	LHS Foundation Ch. 120 to 150.00 mt	1.3.6	70 kg/cm2	80.00	78.52	
	1444						75.56		
4.2	1445						80.00		do
	1446	23-01-2021	30-01-2021	LHS Foundation Ch. 120 to 150.00 mt	1.3.6	70 kg/cm2	75.56	78.52	
	1447						80.00		
5	1448						75.56		do
	1449	25-01-2021	1/2/2021	LHS Horizontal Band (Middle)	1.3.6	70 kg/cm2	75.56	74.08	
	1450			Ch. 0.00 to 150.00 mt			71.11		
6	1451						75.56		do
	1452	26-01-2021	2/2/2021	LHS top band Ch 0.00 to 150.00 mt	1.3.6	70 kg/cm2	75.56	77.04	
	1453						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	3002						84.44		No. WRD/WD XI/ SD IV/ F.cf/182/2020-21. DATED: 10-03-2021
	3003	3/3/2021	10/3/2021	LHS Foundation Ch. 160 to 200.00 m	1.3.6	70 kg/cm ²	84.44	84.44	
	3004						84.44		
1.2	3005						75.56		do
	3006	3/3/2021	10/3/2021	LHS Foundation Ch. 160 to 200.00 m	1.3.6	70 kg/cm ²	80.00	78.52	
	3007						80.00		
2	3008						80.00		do
	3009	4/3/2021	11/3/2021	RHS Foundation Ch. 0 to 30.00 m	1.3.6	70 kg/cm ²	75.56	77.04	
	3010						75.56		
3.1	3011						80.00		do
	3012	5/3/2021	12/3/2021	RHS Foundation Ch. 30 to 90.00 m	1.3.6	70 kg/cm ²	80.00	78.52	
	3013						75.56		
3.2	3014						80.00		do
	3015	5/3/2021	12/3/2021	RHS Foundation Ch. 30 to 90.00 m	1.3.6	70 kg/cm ²	75.56	78.52	
	3016						80.00		
4.1	3017						75.56		do
	3018	6/3/2021	13-03-2021	RHS Foundation Ch. 90 to 160.00 m	1.3.6	70 kg/cm ²	75.56	74.08	
	3019			and Vertical bands LHS/RHS			71.11		
4.2	3020						75.56		do
	3021	6/3/2021	13-03-2021	RHS Foundation Ch. 90 to 160.00 m	1.3.6	70 kg/cm ²	75.56	77.04	
	3022			and Vertical bands LHS/RHS			80.00		
5	3023						80.00		do
	3024	9/3/2021	16-03-2021	Horizontal middle belt RHS from Ch. 0 to	1.3.6	70 kg/cm ²	84.44	82.96	
	3025			160 m RHS Ch. 160 to 200 m LHS			84.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	6498						88.89		No. WRD/WD XI/ SD IV/
	6499	23-04-2021	30-04-2021	RHS Foundation Ch. 165 to 200.00 m	1.3.6	70 kg/cm ²	84.44	85.92	F.cf/50/2021-22.
	6500						84.44		DATED: 30-04-2021
1.2	6501						84.44		
	6502	23-04-2021	30-04-2021	RHS Foundation Ch. 165 to 200.00 m	1.3.6	70 kg/cm ²	88.89	84.44	do
	6503						80.00		
2	6504			Horizontal middle belt (RHS) and vertical bands Ch.165 mt to 200 mt. Horizontal top belt (LHS) ch.165 mt to 200 mt and Vertical			84.44		
	6505	26-04-2021	3/5/2021		1.3.6	70 kg/cm ²	84.44	84.44	do
	6506						84.44		
3	6507						80.00		
	6508	28-04-2021	5/5/2021	Horizontal top belt (RHS) Ch. 0 mt to Ch. 160 mt and Ch.165 m to Ch. 200 m	1.3.6	70 kg/cm ²	80.00	81.48	do
	6509						84.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER