

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1454						115.56		No. WRD/WD XI/ SD IV/ F.cf/76/2020-21. DATED: 27-01-2021
	1455	20-01-2021	17-02-2021	LHS Foundation Ch. 0 to 30.00 mt	1.3.6	100 kg/cm2	115.56	115.56	
	1456						115.56		
2	1457						115.56		do
	1458	21-01-2021	18-02-2021	LHS Foundation Ch. 30 to 60.00 mt	1.3.6	100 kg/cm2	115.56	114.08	
	1459						111.11		
3.1	1460						115.56		do
	1461	22-01-2021	19-02-2021	LHS Foundation Ch. 60 to 120.00 mt	1.3.6	100 kg/cm2	115.56	114.08	
	1462						111.11		
3.2	1463						115.56		do
	1464	22-01-2021	19-02-2021	LHS Foundation Ch. 60 to 120.00 mt	1.3.6	100 kg/cm2	115.56	115.56	
	1465						115.56		
4.1	1466						115.56		do
	1467	23-01-2021	20-02-2021	LHS Foundation Ch. 120 to 150.00 mt	1.3.6	100 kg/cm2	115.56	114.08	
	1468						111.11		
4.2	1469						115.56		do
	1470	23-01-2021	20-02-2021	LHS Foundation Ch. 120 to 150.00 mt	1.3.6	100 kg/cm2	115.56	115.56	
	1471						115.56		
5	1472						111.11		do
	1473	25-01-2021	22-02-2021	LHS Horizontal Band (Middle) Ch. 0.00 to 150.00 mt	1.3.6	100 kg/cm2	115.56	114.08	
	1474						115.56		
6	1475						115.56		do
	1476	26-01-2021	23-02-2021	LHS top band Ch 0.00 to 150.00 mt	1.3.6	100 kg/cm2	115.56	115.56	
	1477						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	3026						115.56		No. WRD/WD XI/ SD IV/ F.cf/182/2020-21. DATED: 10-03-2021
	3027	3/3/2021	31-03-2021	LHS Foundation Ch. 160 to 200.00 m	1.3.6	100 kg/cm ²	115.56	115.56	
	3028						115.56		
1.2	3029						115.56		do
	3030	3/3/2021	31-03-2021	LHS Foundation Ch. 160 to 200.00 m	1.3.6	100 kg/cm ²	115.56	114.08	
	3031						111.11		
2	3032						115.56		do
	3033	4/3/2021	1/4/2021	RHS Foundation Ch. 0 to 30.00 m	1.3.6	100 kg/cm ²	115.56	115.56	
	3034						115.56		
3.1	3035						111.11		do
	3036	5/3/2021	2/4/2021	RHS Foundation Ch. 30 to 90.00 m	1.3.6	100 kg/cm ²	115.56	114.08	
	3037						115.56		
3.2	3038						115.56		do
	3039	5/3/2021	2/4/2021	RHS Foundation Ch. 30 to 90.00 m	1.3.6	100 kg/cm ²	115.56	115.56	
	3040						115.56		
4.1	3041						115.56		do
	3042	6/3/2021	3/4/2021	RHS Foundation Ch. 90 to 160.00 m	1.3.6	100 kg/cm ²	115.56	115.56	
	3043			and Vertical bands LHS/RHS			115.56		
4.2	3044						115.56		do
	3045	6/3/2021	3/4/2021	RHS Foundation Ch. 90 to 160.00 m	1.3.6	100 kg/cm ²	115.56	114.08	
	3046			and Vertical bands LHS/RHS			111.11		
5	3047						115.56		do
	3048	9/3/2021	7/4/2021	Horizontal middle belt RHS from Ch. 0 to	1.3.6	100 kg/cm ²	115.56	114.08	
	3049			160 m RHS Ch. 160 to 200 m LHS			111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah sides in the Survey No. 44/2 and 36/1 in the said property at Shirshirem, Borim of shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	6510						115.56		No. WRD/WD XI/ SD IV/
	6511	23-04-2021	22-05-2021	RHS Foundation Ch. 165 to 200.00 m	1.3.6	100 kg/cm ²	115.56	114.08	F.cf/50/2021-22.
	6512						111.11		DATED: 30-04-2021
1.2	6513						115.56		
	6514	23-04-2021	22-05-2021	RHS Foundation Ch. 165 to 200.00 m	1.3.6	100 kg/cm ²	115.56	115.56	do
	6515						115.56		
2	6516			Horizontal middle belt (RHS) and Vertical bands Ch. 165 mt to Ch. 200 mt. Horizontal top belt (LHS) Ch. 160 mt to Ch. 200 mt and Vertical bands			111.11		
	6517	26-04-2021	24-05-2021		1.3.6	100 kg/cm ²	115.56	114.08	do
	6518						115.56		
3	6519						115.56		
	6520	28-04-2021	26-05-2021	Horizontal top belt (RHS) Ch. 0 mt to Ch. 160 mt and Ch.165 m to Ch. 200 m	1.3.6	100 kg/cm ²	115.56	115.56	do
	6521						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER