

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Yeshwant Nagar in Ponda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	1820						75.56		No. WRD/WD XI/SD IV/ F.CF/110/2020-21. DATED: 10-02-2021
	1821	4/2/2021	11/2/2021	Foundation	1.3.6	70 kg/cm ²	80.00	80.00	
	1822						84.44		
2	1823						75.56		
	1824	5/2/2021	12/2/2021	Wall (1st Lift)	1.3.6	70 kg/cm ²	80.00	77.04	do
	1825						75.56		
3	1826						80.00		
	1827	8/2/2021	15-02-2021	Wall (2nd Lift)	1.3.6	70 kg/cm ²	75.56	78.52	do
	1828						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER