

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent protection for nallah near the house of Ajit Devari at Deulwada in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	2294						75.56		No. WRD/WD XI/ SD IV/ F.cf/162/2020-21. DATED: 02-03-2021
	2295	23-02-2021	2/3/2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	2296						75.56		
2.1	2297						80.00		
	2298	24-02-2021	3/3/2021	Foundation	1.3.6	70 kg/cm2	80.00	78.52	do
	2299						75.56		
2.2	2300						80.00		
	2301	24-02-2021	3/3/2021	Foundation	1.3.6	70 kg/cm2	80.00	78.52	do
	2302						75.56		
3.1	2303						75.56		
	2304	26-02-2021	5/3/2021	Wall	1.3.6	70 kg/cm2	75.56	77.04	do
	2305						80.00		
3.2	2306						75.56		
	2307	26-02-2021	5/3/2021	Wall	1.3.6	70 kg/cm2	75.56	75.56	do
	2308						75.56		
4.1	2309						80.00		
	2310	27-02-2021	6/3/2021	Wall	1.3.6	70 kg/cm2	80.00	78.52	
	2311						75.56		
4.2	2312						75.56		
	2313	27-02-2021	6/3/2021	Wall	1.3.6	70 kg/cm2	75.56	77.04	
	2314						80.00		
5	2315						80.00		
	2316	1/3/2021	8/3/2021	Wall	1.3.6	70 kg/cm2	84.44	81.48	do
	2317						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent protection for nallah near the house of Ajit Devari at Deulwada in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	2318						124.44		No. WRD/WD XI/ SD IV/ F.cf/162/2020-21. DATED: 02-03-2021
	2319	23-02-2021	23-03-2021	Foundation	1.3.6	100 kg/cm2	124.44	125.92	
	2320						128.89		
2.1	2321						124.44		do
	2322	24-02-2021	24-03-2021	Foundation	1.3.6	100 kg/cm2	120.00	122.96	
	2323						124.44		
2.2	2324						124.44		do
	2325	24-02-2021	24-03-2021	Foundation	1.3.6	100 kg/cm2	124.44	124.44	
	2326						124.44		
3.1	2327						124.44		do
	2328	26-02-2021	26-03-2021	Wall	1.3.6	100 kg/cm2	128.89	125.92	
	2329						124.44		
3.2	2330						124.44		do
	2331	26-02-2021	26-03-2021	Wall	1.3.6	100 kg/cm2	120.00	122.96	
	2332						124.44		
4.1	2333						124.44		do
	2334	27-02-2021	27-03-2021	Wall	1.3.6	100 kg/cm2	124.44	124.44	
	2335						124.44		
4.2	2336						124.44		do
	2337	27-02-2021	27-03-2021	Wall	1.3.6	100 kg/cm2	124.44	124.44	
	2338						124.44		
5	2339						120.00		do
	2340	1/3/2021	29-03-2021	Wall	1.3.6	100 kg/cm2	124.44	121.48	
	2341						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER