

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Bom Jesus Chapel at Dandi in V.P. Agassaim in St. Andre Constituency Goa.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	944						164.44		No. MI/SD IV/ WD I/ WRD/F.38/2020-21/509. DATED: 15-01-2021
	945	21-12-2020	18-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	167.41	
	946						168.89		
1.2	947						168.89		
	948	21-12-2020	18-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	164.44	167.41	do
	949						168.89		
1.3	950						168.89		
	951	21-12-2020	18-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	170.37	do
	952						168.89		
2.1	953						173.33		
	954	23-12-2020	20-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	171.85	do
	955						168.89		
2.2	956						168.89		
	957	23-12-2020	20-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	170.37	do
	958						173.33		
2.3	959						173.33		
	960	23-12-2020	20-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	170.37	do
	961						168.89		
3.1	962						173.33		
	963	26-12-2020	23-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	173.33	do
	964						173.33		
3.2	965						173.33		
	966	26-12-2020	23-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	177.78	174.81	do
	967						173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Bom Jesus Chapel at Dandi in V.P. Agassaim in St. Andre Constituency Goa.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	968						177.78		No. MI/SD IV/ WD I/
	969	26-12-2020	23-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	174.81	WRD/F.38/2020-21/509.
	970						173.33		DATED: 15-01-2021
4.1	971						173.33		
	972	28-12-2020	25-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	173.33	do
	973						173.33		
4.2	974						173.33		
	975	28-12-2020	25-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	171.85	do
	976						173.33		
4.3	977						173.33		
	978	28-12-2020	25-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	173.33	do
	979						173.33		
5.1	980						175.33		
	981	30-12-2020	27-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	175.33	176.15	do
	982						177.78		
5.2	983						177.78		
	984	30-12-2020	27-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	177.78	176.96	do
	985						175.33		
5.3	986						164.44		
	987	30-12-2020	27-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	167.41	do
	988						168.89		
6.1	989						173.33		
	990	31-12-2020	28-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	171.85	do
	991						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Bom Jesus Chapel at Dandi in V.P. Agassaim in St. Andre Constituency Goa.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	992						168.89		No. MI/SD IV/ WD I/
	993	31-12-2020	28-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	171.85	WRD/F.38/2020-21/509.
	994						173.33		DATED: 15-01-2021
6.3	995						173.33		
	996	31-12-2020	28-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	173.33	173.33	do
	997						173.33		
7.1	998						173.33		
	999	2/1/2021	30-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	171.85	do
	1000						173.33		
7.2	1001						173.33		
	1002	2/1/2021	30-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	168.89	170.37	do
	1003						168.89		
7.3	1004						160.00		
	1005	2/1/2021	30-01-2021	Foundation and Plinth	1.2.4	150 kg/cm2	164.44	162.96	do
	1006						164.44		
8.1	1007						164.44		
	1008	4/1/2021	1/2/2021	Foundation and Plinth	1.2.4	150 kg/cm2	164.44	164.44	do
	1009						164.44		
8.2	1010						164.44		
	1011	4/1/2021	1/2/2021	Foundation and Plinth	1.2.4	150 kg/cm2	164.44	165.92	do
	1012						168.89		
8.3	1013						164.44		
	1014	4/1/2021	1/2/2021	Foundation and Plinth	1.2.4	150 kg/cm2	160.00	162.96	do
	1015						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Bom Jesus Chapel at Dandi in V.P. Agassaim in St. Andre Constituency Goa.

SAMPLE SENT BY: AE, SD IV, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
9.1	1016						164.44		No. MI/SD IV/ WD I/
	1017	6/1/2021	3/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	164.44	165.92	WRD/F.38/2020-21/509.
	1018						168.89		DATED: 15-01-2021
9.2	1019						164.44		
	1020	6/1/2021	3/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	160.00	162.96	do
	1021						164.44		
9.3	1022						164.44		
	1023	6/1/2021	3/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	168.89	167.41	do
	1024						168.89		
10.1	1025						168.89		
	1026	8/1/2021	5/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	168.89	168.89	do
	1027						168.89		
10.2	1028						164.44		
	1029	8/1/2021	5/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	160.00	164.44	do
	1030						168.89		
10.3	1031						164.44		
	1032	8/1/2021	5/2/2021	Foundation and Plinth	1.2.4	150 kg/cm ²	164.44	165.92	do
	1033						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER