

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and side stabilization of nallah from upper jetty upto Khapreshwar Temple Jetty at Vasco in Mormugao Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	1922						168.89		No. WRD/WD II/ SD II/ F.03/242/2020-21. DATED: 19-02-2021
	1923	22-01-2021	19-02-2021	Wall Foundation (LHS)	1.2.4	150 kg/cm ²	164.44	167.41	
	1924						168.89		
1.2	1925						164.44		do
	1926	22-01-2021	19-02-2021	Wall Foundation (LHS)	1.2.4	150 kg/cm ²	164.44	165.92	
	1927						168.89		
1.3	1928						164.44		do
	1929	22-01-2021	19-02-2021	Wall Foundation (LHS)	1.2.4	150 kg/cm ²	168.89	167.41	
	1930						168.89		
1.4	1931						164.44		do
	1932	22-01-2021	19-02-2021	Wall Foundation (LHS)	1.2.4	150 kg/cm ²	164.44	165.92	
	1933						168.89		
2.1	1934						168.89		do
	1935	23-01-2021	20-02-2021	Wall Foundation (RHS)	1.2.4	150 kg/cm ²	164.44	167.41	
	1936						168.89		
2.2	1937						168.89		do
	1938	23-01-2021	20-02-2021	Wall Foundation (RHS)	1.2.4	150 kg/cm ²	168.89	168.89	
	1939						168.89		
2.3	1940						164.44		do
	1941	23-01-2021	20-02-2021	Wall Foundation (RHS)	1.2.4	150 kg/cm ²	164.44	165.92	
	1942						168.89		
2.4	1943						168.89		do
	1944	23-01-2021	20-02-2021	Wall Foundation (RHS)	1.2.4	150 kg/cm ²	168.89	167.41	
	1945						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and side stabilization of nallah from upper jetty upto Khapreshwar Temple Jetty at Vasco in Mormugao Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	1946						160.00		No. WRD/WD II/ SD II/ F.03/242/2020-21. DATED: 19-02-2021
	1947	24-01-2021	21-02-2021	Wall above Foundation 1st lift (RHS)	1.2.4	150 kg/cm2	164.44	161.48	
	1948						160.00		
3.2	1949						164.44		do
	1950	24-01-2021	21-02-2021	Wall above Foundation 1st lift (RHS)	1.2.4	150 kg/cm2	155.56	160.00	
	1951						160.00		
3.3	1952						164.44		do
	1953	24-01-2021	21-02-2021	Wall above Foundation 1st lift (RHS)	1.2.4	150 kg/cm2	164.44	165.92	
	1954						168.89		
3.4	1955						168.89		do
	1956	24-01-2021	21-02-2021	Wall above Foundation 1st lift (RHS)	1.2.4	150 kg/cm2	164.44	167.41	
	1957						168.89		
4.1	1958						168.89		do
	1959	25-01-2021	22-02-2021	Wall above Foundation 1st lift (LHS)	1.2.4	150 kg/cm2	168.89	167.41	
	1960						164.44		
4.2	1961						164.44		do
	1962	25-01-2021	22-02-2021	Wall above Foundation 1st lift (LHS)	1.2.4	150 kg/cm2	164.44	165.92	
	1963						168.89		
4.3	1964						168.89		do
	1965	25-01-2021	22-02-2021	Wall above Foundation 1st lift (LHS)	1.2.4	150 kg/cm2	168.89	168.89	
	1966						168.89		
4.4	1967						168.89		do
	1968	25-01-2021	22-02-2021	Wall above Foundation 1st lift (LHS)	1.2.4	150 kg/cm2	168.89	167.41	
	1969						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and side stabilization of nallah from upper jetty upto Khapreshwar Temple Jetty at Vasco in Mormugao Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	1970						164.44		No. WRD/WD II/ SD II/
	1971	26-01-2021	23-02-2021	Final Lift	1.2.4	150 kg/cm ²	164.44	165.92	F.03/242/2020-21.
	1972						168.89		DATED: 19-02-2021
5.2	1973						168.89		
	1974	26-01-2021	23-02-2021	Final Lift	1.2.4	150 kg/cm ²	168.89	167.41	do
	1975						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER