

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to Drain near Laximikant Khedekar house ward No. 3, V.P. Priol of Priol Constituency of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2774						111.11		No. WRD/WD XI/ SD IV/ F.CF/174/2020-21. DATED: 09-03-2021
	2775	3/3/2021	10/3/2021	For Base	1.2.4	100 kg/cm2	111.11	109.63	
	2776						106.67		
2	2777						106.67		
	2778	4/3/2021	11/3/2021	For Base	1.2.4	100 kg/cm2	106.67	106.67	do
	2779						106.67		
3	2780						106.67		
	2781	6/3/2021	13-03-2021	For Base	1.2.4	100 kg/cm2	106.67	108.15	do
	2782						111.11		
4	2783						111.11		
	2784	8/3/2021	15-03-2021	For Base & side wall of drain	1.2.4	100 kg/cm2	106.67	109.63	do
	2785						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER