

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall for the nallah in Sy.No. 60/4, 60/1 & 55/4 at Poriehat- Verna in ward No. 2 in Nuvem Constituency of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Aquem Baixo, Rawanfond,Salcete Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	854						173.33		No. WRD/ SD I/WD II/ F.Esst/ 726 /2020-21. <b>DATED: 29-12-2020</b>
	855	15-12-2020	12/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	856						168.89		
1.2	857						168.89		do
	858	15-12-2020	12/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	859						173.33		
2.1	860						173.33		do
	861	16-12-2020	13-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	862						168.89		
2.2	863						173.33		do
	864	16-12-2020	13-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	865						173.33		
3.1	866						168.89		do
	867	20-12-2020	17-01-2021	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	868						173.33		
3.2	869						173.33		do
	870	20-12-2020	17-01-2021	Wall	1.2.4	150 kg/cm2	173.33	171.85	
	871						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**