

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Maintenance & Repair of Open canal from Ch. 320 mt to 570 mt and its branch 150 mt of Lift irrigation Scheme Quinamol in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	1754						120.00		No. WRD/ SD I/ Wd XII/ F. 47/438/2020-21. DATED: 04-02-2021
	1755	30-01-2021	6/2/2021	Ch. 320 mt to Ch. 380 mt	1.2.4	100 kg/cm ²	124.44	121.48	
	1756						120.00		
2	1757						120.00		do
	1758	1/2/2021	8/2/2021	Ch. 380 mt to Ch. 440 mt	1.2.4	100 kg/cm ²	120.00	120.00	
	1759						120.00		
3	1760						111.11		do
	1761	2/2/2021	9/2/2021	Ch. 440 mt to Ch. 500 mt	1.2.4	100 kg/cm ²	115.56	114.08	
	1762						115.56		
4	1763						111.11		do
	1764	3/2/2021	10/2/2021	Ch. 500 mt to Ch. 560 mt	1.2.4	100 kg/cm ²	115.56	114.08	
	1765						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Maintenance & Repair of Open canal from Ch. 320 mt to 570 mt and its branch 150 mt of Lift irrigation Scheme Quinamol in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	1766						164.44		No. WRD/ SD I/ Wd XII/
	1767	30-01-2021	27-02-2021	Ch. 320 mt to Ch. 380 mt	1.2.4	150 kg/cm ²	164.44	165.92	F. 47/438/2020-21.
	1768						168.89		DATED: 04-02-2021
2	1769						168.89		
	1770	1/2/2021	1/3/2021	Ch. 380 mt to Ch. 440 mt	1.2.4	150 kg/cm ²	164.44	167.41	do
	1771						168.89		
3	1772						168.89		
	1773	2/2/2021	2/3/2021	Ch. 440 mt to Ch. 500 mt	1.2.4	150 kg/cm ²	168.89	167.41	do
	1774						164.44		
4	1775						164.44		
	1776	3/2/2021	3/3/2021	Ch. 500 mt to Ch. 560 mt	1.2.4	150 kg/cm ²	164.44	165.92	do
	1777						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER