

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of sluice gate and strengthening of bund in Sy.No. 109 in Village Deussua of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2132						168.89		No. WRD/SD I/WD II/ F.Estt/853/2021-22. <b>DATED: 22-02-2021.</b>
	2133	25-01-2021	22-02-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	2134						168.89		
2	2135						168.89		do
	2136	27-01-2021	24-02-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	2137						168.89		
3.1	2138						164.44		do
	2139	28-01-2021	25-02-2021	Wall & Foundation	1.2.4	150 kg/cm2	164.44	162.96	
	2140						160.00		
3.2	2141						164.44		do
	2142	28-01-2021	25-02-2021	Wall & Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	2143						164.44		
4.1	2144						168.89		do
	2145	29-01-2021	26-02-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	2146						164.44		
4.2	2147						164.44		do
	2148	29-01-2021	26-02-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	162.96	
	2149						160.00		
5.1	2150						164.44		do
	2151	30-01-2021	27-02-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	164.44	
	2152						164.44		
5.2	2153						168.89		do
	2154	30-01-2021	27-02-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	2155						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of sluice gate and strengthening of bund in Sy.No. 109 in Village Deussua of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	2156						168.89		No. WRD/SD I/WD II/ F.Estt/853/2021-22. <b>DATED: 22-02-2021.</b>
	2157	1/2/2021	1/3/2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	150.74	
	2158						114.44		
6.2	2159						168.89		do
	2160	1/2/2021	1/3/2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	
	2161						164.44		
7.1	2162						168.89		do
	2163	2/2/2021	2/3/2021	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	2164						168.89		
7.2	2165						168.89		do
	2166	2/2/2021	2/3/2021	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	2167						164.44		
8.1	2168						168.89		do
	2169	4/2/2021	4/3/2021	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	2170						168.89		
8.2	2171						168.89		do
	2172	4/2/2021	4/3/2021	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	2173						168.89		
9.1	2174						168.89		do
	2175	5/2/2021	5/3/2021	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	2176						168.89		
9.2	2177						168.89		do
	2178	5/2/2021	5/3/2021	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	2179						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**