

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall in Sy.No. 146/8 in Verna Village Panchayat in Verna Village in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1.1	3353						164.44		No. WRD/SD I/WD II/ F.Estt/98/2021-22. <b>DATED: 16-03-2021.</b>
	3354	19-02-2021	19-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	3355						168.89		
1.2	3356						168.89		
	3357	19-02-2021	19-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	do
	3358						164.44		
2.1	3359						168.89		
	3360	20-02-2021	20-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	do
	3361						168.89		
2.2	3362						168.89		
	3363	20-02-2021	20-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	do
	3364						164.44		
3.1	3365						173.33		
	3366	22-02-2021	22-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	168.89	do
	3367						168.89		
3.2	3368						168.89		
	3369	22-02-2021	22-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	do
	3370						168.89		
4.1	3371						177.78		
	3372	23-02-2021	23-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	177.78	176.30	do
	3373						173.33		
4.2	3374						177.78		
	3375	23-02-2021	23-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	177.78	177.78	do
	3376						177.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall in Sy.No. 146/8 in Verna Village Panchayat in Verna Village in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
5.1	3377						164.44		No. WRD/SD I/WD II/ F.Estt/98/2021-22. <b>DATED: 16-03-2021.</b>
	3378	24-02-2021	24-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	165.92	
	3379						164.44		
5.2	3380						164.44		do
	3381	24-02-2021	24-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	3382						168.89		
5.3	3383						168.89		do
	3384	24-02-2021	24-03-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	3385						164.44		
6.1	3386						168.89		do
	3387	25-02-2021	25-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	3388						164.44		
6.2	3389						168.89		do
	3390	25-02-2021	25-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	
	3391						168.89		
7.1	3392						177.78		do
	3393	26-02-2021	26-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	179.26	
	3394						177.78		
7.2	3395						182.22		do
	3396	26-02-2021	26-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	177.78	179.26	
	3397						177.78		
8.1	3398						191.11		do
	3399	1/3/2021	29-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	186.67	188.15	
	3400						186.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall in Sy.No. 146/8 in Verna Village Panchayat in Verna Village in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
8.2	3401						186.67		No. WRD/SD I/WD II/ F.Estt/98/2021-22. <b>DATED: 16-03-2021.</b>
	3402	1/3/2021	29-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	186.67	186.67	
	3403						186.67		
9.1	3404						182.22		do
	3405	2/3/2021	30-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	180.74	
	3406						177.78		
9.2	3407						182.22		do
	3408	2/3/2021	30-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	182.22	
	3409						182.22		
9.3	3410						177.78		do
	3411	2/3/2021	30-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	179.26	
	3412						177.78		
10.1	3413						177.78		do
	3414	3/3/2021	31-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	177.78	177.78	
	3415						177.78		
10.2	3416						182.22		do
	3417	3/3/2021	31-03-2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	183.70	
	3418						186.67		
11.1	3419						186.67		do
	3420	4/3/2021	1/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	186.67	186.67	
	3421						186.67		
11.2	3422						186.67		do
	3423	4/3/2021	1/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	185.19	
	3424						186.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall in Sy.No. 146/8 in Verna Village Panchayat in Verna Village in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
12.1	3425						182.22		No. WRD/SD I/WD II/ F.Estt/98/2021-22. <b>DATED: 16-03-2021.</b>
	3426	5/3/2021	2/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	186.67	185.19	
	3427						186.67		
12.2	3428						182.22		do
	3429	5/3/2021	2/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	183.70	
	3430						186.67		
13.1	3431						182.22		do
	3432	6/3/2021	3/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	183.70	
	3433						186.67		
13.2	3434						182.22		do
	3435	6/3/2021	3/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	182.22	
	3436						182.22		
14.1	3437						182.22		do
	3438	8/3/2021	5/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	186.67	185.19	
	3439						186.67		
14.2	3440						182.22		do
	3441	8/3/2021	5/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	183.70	
	3442						186.67		
14.3	3443						182.22		do
	3444	8/3/2021	5/4/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	182.22	183.70	
	3445						186.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**