

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Stabilization and Development of Nallah in Sy.No. 29 & 31 at Karally Paroda in Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	6620						164.44		No. WRD/SD I/WD II/ F.Estt/84/2021-22. <b>DATED: 03-05-2021</b>
	6621	28-04-2021	26-05-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	164.44	
	6622						164.44		
2	6623						168.89		
	6624	29-04-2021	27-05-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	6625						164.44		
3	6626						164.44		
	6627	30-04-2021	28-05-2021	Foundation & Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	6628						164.44		
4	6629						164.44		
	6630	1/5/2021	29-05-2021	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	6631						168.89		