

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah at Dhobiwada from Sy.No. 145 to Sy.No. 35 in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|--------------|--------------|--------------|-------------------------------------|----------------|-----------------|--------------------|------------------|---|
| 1.1 | F.06/06/2023 | | | | | | 231.11 | | No. WRD/ SD II/ WD II/ F.03/303/2023-24. DATED: 15-12-2023 |
| | F.06/07/2023 | 18-11-2023 | 16-12-2023 | Foundation LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm2 | 217.78 | 225.19 | |
| | F.06/08/2023 | | | | | | 226.67 | | |
| 1.2 | F.06/09/2023 | | | | | | 235.56 | | |
| | F.06/10/2023 | 18-11-2023 | 16-12-2023 | Foundation LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm2 | 226.67 | 228.15 | do |
| | F.06/11/2023 | | | | | | 222.22 | | |
| 2 | F.06/11/2023 | | | | | | 235.56 | | |
| | F.06/12/2023 | 20-11-2023 | 18-12-2023 | Foundation LHS Ch. 30.00 to 48.70 m | 1.2.4 | 210 kg/cm2 | 231.11 | 229.63 | do |
| | F.06/13/2023 | | | | | | 222.22 | | |
| 3.1 | F.06/14/2023 | | | | | | 213.33 | | |
| | F.06/15/2023 | 22-11-2023 | 20-12-2023 | Foundation RHS Ch.0.00 to 30.00 m | 1.2.4 | 210 kg/cm2 | 235.56 | 229.63 | do |
| | F.06/16/2023 | | | | | | 240.00 | | |
| 3.2 | F.06/17/2023 | | | | | | 235.56 | | |
| | F.06/18/2023 | 22-11-2023 | 20-12-2023 | Foundation RHS Ch.0.00 to 30.00 m | 1.2.4 | 210 kg/cm2 | 217.78 | 228.15 | do |
| | F.06/19/2023 | | | | | | 231.11 | | |
| 4 | F.06/20/2023 | | | | | | 231.11 | | |
| | F.06/21/2023 | 25-11-2023 | 23-12-2023 | Foundation RHS Ch.30.00 to 41.00 m | 1.2.4 | 210 kg/cm2 | 226.67 | 229.63 | do |
| | F.06/22/2023 | | | | | | 231.11 | | |
| 5.1 | F.06/23/2023 | | | | | | 226.67 | | |
| | F.06/24/2023 | 27-11-2023 | 26-12-2023 | 1st Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm2 | 222.22 | 226.67 | do |
| | F.06/25/2023 | | | | | | 231.11 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah at Dhobiwada from Sy.No. 145 to Sy.No. 35 in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | | |
|--------------------|--------------|--------------|--------------|-----------------------------------|----------------|------------------------|--------------------------------|------------------------------|---|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm ² | Avg. Comp Kg/cm ² | LETTER No / DATED |
| 5.2 | F.06/26/2023 | | | | | | 235.56 | | No. WRD/ SD II/ WD II/ F.03/303/2023-24. DATED: 15-12-2023 |
| | F.06/27/2023 | 27-11-2023 | 26-12-2023 | 1st Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 226.67 | 229.63 | |
| | F.06/28/2023 | | | | | | 226.67 | | |
| 6 | F.06/29/2023 | | | | | | 240.00 | | |
| | F.06/30/2023 | 28-11-2023 | 26-12-2023 | 1st Lift LHS Ch. 30.00 to 48.70 m | 1.2.4 | 210 kg/cm ² | 217.78 | 229.63 | do |
| | F.06/31/2023 | | | | | | 231.11 | | |
| 7.1 | F.06/32/2023 | | | | | | 235.56 | | |
| | F.06/33/2023 | 30-11-2023 | 28-12-2023 | 2nd Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 226.67 | 228.15 | do |
| | F.06/34/2023 | | | | | | 222.22 | | |
| 7.2 | F.06/35/2023 | | | | | | 231.11 | | |
| | F.06/36/2023 | 30-11-2023 | 28-12-2023 | 2nd Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 226.67 | 228.15 | do |
| | F.06/37/2023 | | | | | | 226.67 | | |
| 8 | F.06/38/2023 | | | | | | 231.11 | | |
| | F.06/39/2023 | 1/12/2023 | 29-12-2023 | 2nd Lift LHS Ch. 30.00 to 48.70 m | 1.2.4 | 210 kg/cm ² | 226.67 | 226.67 | do |
| | F.06/40/2023 | | | | | | 222.22 | | |
| 9.1 | F.06/41/2023 | | | | | | 217.78 | | |
| | F.06/42/2023 | 2/12/2023 | 30-12-2023 | 3rd Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 231.11 | 228.15 | do |
| | F.06/43/2023 | | | | | | 235.56 | | |
| 9.2 | F.06/44/2023 | | | | | | 226.67 | | |
| | F.06/45/2023 | 2/12/2023 | 30-12-2023 | 3rd Lift LHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 240.00 | 225.19 | do |
| | F.06/46/2023 | | | | | | 208.89 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the nallah at Dhobiwada from Sy.No. 145 to Sy.No. 35 in Dabolim Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogol- Margao- Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | | |
|--------------------|--------------|--------------|--------------|-----------------------------------|----------------|------------------------|--------------------------------|------------------------------|---|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm ² | Avg. Comp Kg/cm ² | LETTER No / DATED |
| 10 | F.06/47/2023 | | | | | | 226.67 | | No. WRD/ SD II/ WD II/ F.03/303/2023-24. DATED: 15-12-2023 |
| | F.06/48/2023 | 5/12/2023 | 2/1/2024 | 3rd Lift LHS Ch. 30.00 to 48.70 m | 1.2.4 | 210 kg/cm ² | 235.56 | 225.19 | |
| | F.06/49/2023 | | | | | | 213.33 | | |
| 11.1 | F.06/50/2023 | | | | | | 231.11 | | do |
| | F.06/51/2023 | 7/12/2023 | 4/1/2024 | 1st Lift RHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 217.78 | 223.70 | |
| | F.06/52/2023 | | | | | | 222.22 | | |
| 11.2 | F.06/53/2023 | | | | | | 226.67 | | do |
| | F.06/54/2023 | 7/12/2023 | 4/1/2024 | 1st Lift RHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 222.22 | 225.19 | |
| | F.06/55/2023 | | | | | | 226.67 | | |
| 12 | F.06/56/2023 | | | | | | 231.11 | | do |
| | F.06/57/2023 | 8/12/2023 | 5/1/2024 | 1st Lift RHS Ch. 30.00 to 41.00 m | 1.2.4 | 210 kg/cm ² | 235.56 | 229.63 | |
| | F.06/58/2023 | | | | | | 222.22 | | |
| 13 | F.06/59/2023 | | | | | | 226.67 | | do |
| | F.06/60/2023 | 9/12/2023 | 6/1/2024 | 2nd Lift RHS Ch. 0.00 to 30.00 m | 1.2.4 | 210 kg/cm ² | 240.00 | 232.59 | |
| | F.06/61/2023 | | | | | | 231.11 | | |
| 14 | F.06/62/2023 | | | | | | 226.67 | | do |
| | F.06/63/2023 | 11/12/2023 | 8/1/2024 | 2nd Lift RHS Ch. 30.00 to 41.00 m | 1.2.4 | 210 kg/cm ² | 226.67 | 229.63 | |
| | F.06/64/2023 | | | | | | 235.56 | | |
| 15 | F.06/65/2023 | | | | | | 226.67 | | do |
| | F.06/66/2023 | 14-12-2023 | 11/1/2024 | 3rd Lift RHS Ch. 0.00 to 41.00 m | 1.2.4 | 210 kg/cm ² | 222.22 | 226.67 | |
| | F.06/67/2023 | | | | | | 231.11 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER