

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of RCC box culvert over main canal of SIP at Ch. 3.090 km at Cotarli Village of Sanguem Constituency.

SAMPLE SENT BY: AE, SD III, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.75/01/2025						364.44		No.WRD/WD X/SD III/ W.F. 01/210/2025-26. DATED: 26-11-2025.
	F.75/02/2025	13-11-2025	11/12/2025	All works upto floor V level	M20	305 kg/cm2	377.77	367.40	
	F.75/03/2025						360.00		
1.2	F.75/04/2025						351.11		do
	F.75/05/2025	13-11-2025	11/12/2025	All works upto floor V level	M20	305 kg/cm2	368.89	364.44	
	F.75/06/2025						373.33		
1.3	F.75/07/2025						368.89		do
	F.75/08/2025	13-11-2025	11/12/2025	All works upto floor V level	M20	305 kg/cm2	364.44	362.96	
	F.75/09/2025						355.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Re- Construction of RCC box culvert over main canal of SIP at Ch. 3.090 km at Cotarli Village of Sanguem Constituency.

SAMPLE SENT BY: AE, SD III, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	F.75/10/2025						555.35		No.WRD/WD X/SD III/ W.F. 01/211/2025-26. DATED: 26-11-2025.
	F.75/11/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	559.09	
	F.75/12/2025						566.56		
2.2	F.75/13/2025						550.26		do
	F.75/14/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	557.39	
	F.75/15/2025						566.56		
2.3	F.75/16/2025						529.88		do
	F.75/17/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	566.66	554.37	
	F.75/18/2025						566.56		
2.4	F.75/19/2025						566.56		do
	F.75/20/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	572.67	556.37	
	F.75/21/2025						529.88		
2.5	F.75/22/2025						555.35		do
	F.75/23/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	572.67	559.34	
	F.75/24/2025						550.00		
2.6	F.75/25/2025						588.98		do
	F.75/26/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	558.07	
	F.75/27/2025						529.88		
2.7	F.75/28/2025						591.11		do
	F.75/29/2025	15-11-2025	13-12-2025	All works upto floor V level	M40	530 kg/cm2	566.56	562.52	
	F.75/30/2025						529.88		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.75/2025/2025-26/458

. Dated:-27/12/2025

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of RCC box culvert over main canal of SIP at Ch. 3.090 km at Cotarli Village of Sanguem Constituency.

SAMPLE SENT BY: AE, SD III, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.75/31/2025						550.26		No.WRD/WD X/SD III/ W.F. 01/212/2025-26. DATED: 26-11-2025.
	F.75/32/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	560.45	559.09	
	F.75/33/2025						566.56		
3.2	F.75/34/2025						570.64		do
	F.75/35/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	560.45	562.15	
	F.75/36/2025						555.35		
3.3	F.75/37/2025						548.22		do
	F.75/38/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	560.45	558.41	
	F.75/39/2025						566.56		
3.4	F.75/40/2025						570.64		do
	F.75/41/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	550.26	557.05	
	F.75/42/2025						550.26		
3.5	F.75/43/2025						560.45		do
	F.75/44/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	560.79	
	F.75/45/2025						566.56		
3.6	F.75/46/2025						550.26		do
	F.75/47/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	548.22	556.37	
	F.75/49/2025						570.64		
3.7	F.75/50/2025						555.35		do
	F.75/51/2025	20-11-2025	18-12-2025	All works upto floor V level	M40	530 kg/cm2	566.56	557.39	
	F.75/52/2025						550.26		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.75/2025/2025-26/465

. Dated:-29/12/2025

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of RCC box culvert over main canal of SIP at Ch. 3.090 km at Cotarli Village of Sanguem Constituency.

SAMPLE SENT BY: AE, SD III, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.75/53/2025						364.44		No.WRD/WD X/SD III/
	F.75/54/2025	26-11-2025	24-12-2025	All works upto floor V level	M20	305 kg/cm2	377.77	364.44	W.F. 01/219/2025-26.
	F.75/55/2025						351.11		DATED: 04-12-2025.
4.2	F.75/56/2025						364.44		
	F.75/57/2025	26-11-2025	24-12-2025	All works upto floor V level	M20	305 kg/cm2	355.55	360.00	do
	F.75/58/2025						360.00		
4.3	F.75/59/2025						368.89		
	F.75/60/2025	26-11-2025	24-12-2025	All works upto floor V level	M20	305 kg/cm2	355.55	362.96	do
	F.75/61/2025						364.44		
4.4	F.75/62/2025						377.77		
	F.75/63/2025	26-11-2025	24-12-2025	All works upto floor V level	M20	305 kg/cm2	364.44	365.92	do
	F.75/64/2025						355.55		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.75/2025/2025-26/466

. Dated:-29/12/2025

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Re- Construction of RCC box culvert over main canal of SIP at Ch. 3.090 km at Cotarli Village of Sanguem Constituency.

SAMPLE SENT BY: AE, SD III, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.75/65/2025						570.64		No.WRD/WD X/SD III/ W.F. 01/220/2025-26. DATED: 04-12-2025.
	F.75/66/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	548.22	563.84	
	F.75/67/2025						572.67		
5.2	F.75/68/2025						566.56		do
	F.75/69/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	570.64	564.18	
	F.75/70/2025						555.35		
5.3	F.75/71/2025						570.64		do
	F.75/72/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	548.22	559.77	
	F.75/73/2025						560.45		
5.4	F.75/74/2025						572.67		do
	F.75/75/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	550.26	557.05	
	F.75/76/2025						548.22		
5.5	F.75/77/2025						566.56		do
	F.75/78/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	560.45	559.09	
	F.75/79/2025						550.26		
5.6	F.75/80/2025						572.67		do
	F.75/81/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	540.07	556.03	
	F.75/82/2025						555.35		
5.7	F.75/83/2025						570.64		do
	F.75/84/2025	28-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm ²	555.35	558.75	
	F.75/85/2025						550.26		

JUNIOR ENGINEER.

ASSISTANT ENGINEER