

## GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.****NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.**NAME OF THE AGENCY****TESTING PERIOD****28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.76/01/2025						346.66		No.WRD/SD I/WD X/
	F.76/02/2025	18-11-2025	16-12-2025	All works upto floor V level	M20	305 kg/cm2	360.00	352.59	F. 55A/221/2025-26.
	F.76/03/2025						351.11		<b>DATED: 25-11-2025.</b>
1.2	F.76/04/2025						355.55		
	F.76/05/2025	18-11-2025	16-12-2025	All works upto floor V level	M20	305 kg/cm2	342.22	349.63	do
	F.76/06/2025						351.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	F.76/07/2025						540.07		No.WRD/SD I/WD X/ F. 55A/222/2025-26. <b>DATED: 25-11-2025.</b>
	F.76/08/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	529.88	539.39	
	F.76/09/2025						548.22		
2.2	F.76/10/2025						550.26		do
	F.76/11/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	535.99	542.11	
	F.76/12/2025						540.07		
2.3	F.76/13/2025						548.22		do
	F.76/14/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	547.88	
	F.76/15/2025						540.07		
2.4	F.76/16/2025						540.22		do
	F.76/17/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	550.26	546.91	
	F.76/18/2025						550.26		
2.5	F.76/19/2025						555.35		do
	F.76/20/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	560.45	548.56	
	F.76/21/2025						529.88		
2.6	F.76/22/2025						535.99		do
	F.76/23/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	548.22	541.43	
	F.76/24/2025						540.07		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.7	F.76/25/2025						550.26		No.WRD/SD I/WD X/
	F.76/26/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	555.35	548.56	F. 55A/222/2025-26.
	F.76/27/2025						540.07		<b>DATED: 25-11-2025.</b>
2.8	F.76/28/2025						535.99		
	F.76/29/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	548.22	546.52	do
	F.76/30/2025						555.35		
2.9	F.76/31/2025						548.22		
	F.76/32/2025	21-11-2025	22-12-2025	All works upto floor V level	M40	530 kg/cm2	560.45	552.30	do
	F.76/33/2025						548.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**NO.WRD/WDXI/SDIII/TECH/W.F.76/2025/2025-26/469**

**. Dated:-29/12/2025**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
3.1	F.76/34/2025						364.44		No.WRD/SD I/WD X/
	F.76/35/2025	25-11-2025	23-12-2025	All works upto floor V level	M 20	305 kg/cm <sup>2</sup>	355.55	357.03	F. 55A/229/2025-26.
	F.76/36/2025						351.11		<b>DATED: 01-12-2025.</b>
3.2	F.76/37/2025						355.55		
	F.76/38/2025	25-11-2025	23-12-2025	All works upto floor V level	M 20	305 kg/cm <sup>2</sup>	360.00	354.07	do
	F.76/39/2025						346.66		
3.3	F.76/40/2025						355.55		
	F.76/41/2025	25-11-2025	23-12-2025	All works upto floor V level	M 20	305 kg/cm <sup>2</sup>	368.89	358.52	do
	F.76/42/2025						351.11		
3.4	F.76/43/2025						346.66		
	F.76/44/2025	25-11-2025	23-12-2025	All works upto floor V level	M 20	305 kg/cm <sup>2</sup>	360.00	352.59	do
	F.76/45/2025						351.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

NO.WRD/WDXI/SDIII/TECH/W.F.76/2025/2025-26/470  
GOVERNMENT OF GOA

. Dated:-29/12/2025

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
4.1	F.76/46/2025						560.45		No.WRD/SD I/WD X/ F. 55A/230/2025-26. <b>DATED: 01-12-2025.</b>
	F.76/47/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	555.35	560.79	
	F.76/49/2025						566.56		
4.2	F.76/50/2025						566.56		do
	F.76/51/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	550.26	555.01	
	F.76/52/2025						548.22		
4.3	F.76/53/2025						560.45		do
	F.76/54/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	555.35	562.15	
	F.76/55/2025						570.64		
4.4	F.76/56/2025						560.45		do
	F.76/57/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	555.35	557.05	
	F.76/58/2025						555.35		
4.5	F.76/59/2025						548.22		do
	F.76/60/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	560.45	556.37	
	F.76/61/2025						560.45		
4.6	F.76/62/2025						566.65		do
	F.76/63/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	548.22	560.51	
	F.76/64/2025						566.65		
4.7	F.76/65/2025						555.35		do
	F.76/66/2025	27-11-2025	26-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	566.56	562.82	
	F.76/67/2025						566.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

NO.WRD/WDXI/SDIII/TECH/W.F.76/2025/2025-26/471

. Dated:-30/12/2025

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of RCC box culvert over main canal of SIP at Ch. 8.15 km at Naguvem Village of Quepem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
5.1	F.76/68/2025						555.35		No.WRD/SD I/WD X/ F. 55A/236/2025-26. DATED: 04-12-2025.
	F.76/69/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	566.45	559.05	
	F.76/70/2025						555.35		
5.2	F.76/71/2025						535.99		do
	F.76/72/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	560.45	554.33	
	F.76/73/2025						566.56		
5.3	F.76/74/2025						570.64		do
	F.76/75/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	535.99	557.73	
	F.76/76/2025						566.56		
5.4	F.76/77/2025						555.35		do
	F.76/78/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	560.45	557.05	
	F.76/79/2025						555.35		
5.5	F.76/80/2025						570.64		do
	F.76/81/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	550.26	556.37	
	F.76/82/2025						548.22		
5.6	F.76/83/2025						555.35		do
	F.76/84/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	535.99	552.63	
	F.76/85/2025						566.56		
5.7	F.76/86/2025						560.45		do
	F.76/87/2025	2/12/2025	30-12-2025	All works upto floor V level	M40	530 kg/cm <sup>2</sup>	550.26	553.66	
	F.76/88/2025						550.26		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**