

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of R.C.C box conduit near Kenybab hotel in Fatorda Constituency, Salcete, Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogal-Goa.

NAME OF THE AGENCY : M/s Veer Constructions, Khadpaband, Ponda, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	914						146.67		No. 233/SD III/WD III
1	915	10-12-2019	17-12-2019	Bed Concrete below box Ch. (42 - 60)m	1.2.4	140 kg/cm2	142.22	145.19	WRD/19-20/322
	916						146.67		Dt.16/12/2019
	917						177.78		
2	918	12-12-2019	19-12-2019	Bottom slab Ch. (0 -13)m	1.1.5.3	175 kg/cm2	182.22	179.26	do
	919						177.78		
	920						182.22		
3	921	13-12-2019	20-12-2019	Bottom slab Ch. (13-26)m	1.1.5.3	175 kg/cm2	182.22	180.74	do
	922						177.78		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)