

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of R.C.C box conduit near Kenybab hotel in Fatorda Constituency, Salcete, Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogal-Goa.

NAME OF THE AGENCY : M/s Veer Constructions, Khadpaband, Ponda, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1112						182.22		No. 233/SD III/WD III
1	1113	18-12-2019	26-12-2019	Bottom slab Ch. (26-39)m	1.1.5.3	175 kg/cm2	182.22	180.74	WRD/19-20/329
	1114						177.78		Dt.23/12/2019
	1115						177.78		
2	1116	19-12-2019	26-12-2019	Bottom slab Ch. (39 -52)m	1.1.5.3	175 kg/cm2	182.22	179.26	do
	1117						177.78		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)